

## Table of Thresholds from HSW (HS) Regs.

HAZARD CLASSIFICATION (HSNO) OF SUBSTANCE	LOCATION COMPLIANCE CERTIFICATE NEEDED WHEN AMOUNTS OF SUBSTANCE OVER THOSE BELOW
2.1.1A , 2.1.1B	100 kg or 100 m3 for a permanent gas
2.1.2A	3,000 L (aggregate water capacity)
3.1A	20 L
3.1A (petrol, aviation gasoline, and racing gasoline)	50 L
3.1B	Closed containers 100 L (in containers more than 5 L in size) or 250 L (in containers 5 L or less in size) Open containers 50 L
3.1C	500 L (in containers more than 5 L in size) or 1,500 L (in containers 5 L or less in size) Open containers 250 L
3.2A, 3.2B, 3.2C	1 L
4.1.1A	1 kg
4.1.1B	100 kg
4.1.2A, 4.1.2B	1 kg
4.1.2C, 4.1.2D	25 kg
4.1.2E, 4.1.2F, 4.1.2G	50 kg
4.1.3A, 4.1.3B, 4.1.3C	1 kg
4.2A	1 kg
4.2B, 4.2C	25 kg
4.3A	1 kg
4.3B	25 kg
4.3C	50 kg
5.1.1A *	50 kg or 50 L
5.1.1B *	500 kg or 500 L
5.1.1C *	1,000 kg or 1,000 L
5.1.2A *	100 kg non-permanent gas or 200 m3 permanent gas
Oxygen in discrete cylinder or tank –HSR001029	200 m3
Chlorine – HSR1001058	150 kg
5.2A, 5.2B	10 kg
5.2C, 5.2D	25 kg
5.2E, 5.2F	100 kg
6.1A	50 kg or 50 L
6.1B	250 kg or 250 L
6.1C	1,000 kg or 1,000 L
8.2A	50 kg or 50 L
8.2B	250 kg or 250 L

\* Class 5 substances have different thresholds where they are manufactured or used. Table 2